



TECHNICAL INFORMATION

TITLE: SE-325 NEUTRAL-GROUNDING-RESISTOR MONITOR SETTINGS

Substation Identification: _____

Secondary Voltage: _____

SE-325 Model Number and Serial Number: _____

GF TRIP TIME (s):

Setting: _____

GF:

- 4 A
- 2 A
- 0.5 A

MODE:

- SH
- UV

RES:

- 100K
- 20K

RES TRIP LEVEL (Vac):

For RES = 100K
 Range is 100 to 2000 Vac.
 Setting: _____

For RES = 20K
 Range is 20 to 400 Vac.
 Setting: _____

CURRENT TRANSFORMER:

- CT200
- CT200L

SENSING RESISTOR:

- ER-600VC
- ER-5KV
- ER-15KV
- ER-25KV
- ER-35KV

REMOTE INDICATION:

- None
- RK-13
- RK-302
- RK-325
- RK-325I

NGR RATINGS:

Current: _____ A
 Voltage: _____ V

DATE	REV	AUTHOR	DOCUMENT LOCATION	PAGE
2002-Dec-10	1	IN	http://www.startco.ca/library/techinfo/section3/3.7.pdf	1 of 1